




Member of



# Certificate of Conformity with European standards for Components and Systems

Number of Certificate	Valid from dd-mm-yyyy	Valid until dd-mm-yyyy
EN-ST-000261	23-10-2019	22-10-2023

Subject matter of Certificate:

**Alarm transmission equipment  
IRIS-4 160**

Owner of Certificate:

**AddSecure AG  
Bahnhofstrasse 30  
CH-6300 ZUG**

Basis for certification:

**EN 50136-2:2013  
EN 50131-10:2014**

Use, the product disposes of the following parameters:

**Intrusion and hold-up systems**

The tests were carried out at VdS Schadenverhütung GmbH  
and the results are documented in test report:

**181209-AU01 dated 30-10-2019**

VdS Schadenverhütung GmbH  
Certification Body  
Amsterdamer Str. 174  
D-50735 Köln

A company of the German  
Insurance Association (GDV)  
accredited by DAkkS as certifica-  
tion body for fire protection and  
security products

To guarantee the permanent quality of products a regular surveillance of the manufacturing process is performed.

This certificate comprises 4 pages and shall only be reproduced without any modifications and including all enclosures.



Date: 04-11-2019

Managing director

Head of certification body

To Certificate No.: EN-ST-000261

Date : 04-11-2019

The approved component/system comprises the following parts:

Description of component	Type	Applicant's Registration No.	Approval number of component (only complete for system approval)
<p>IRIS-4 160 SPT with screwed plastic enclosure in the variant described below equipped with the common features:</p> <ul style="list-style-type: none"> <li>- Software version V4.6.0</li> <li>- USB connector for local PC configuration in combination with IRIS Toolbox software</li> <li>- 4 resistance supervised inputs</li> <li>- 3 relay outputs (electronically)</li> <li>- Serial interfaces (1x RS-232, 1xRS-232 (TTL), 1x RS-485) with support for special control and indication panels</li> <li>- Dial capture port</li> <li>- Battery backup with 4 NiMh AA size batteries</li> <li>- Bluetooth interconnection for local and wireless device configuration (time limited to 10 min.) via mobile phone or tablet.</li> </ul> <p>Dual path (DP4) variant with support for the following transmission paths:</p> <ul style="list-style-type: none"> <li>- GSM/GPRS (2G)</li> <li>- UMTS (3G)</li> <li>- LTE (4G)</li> </ul> <p>and</p> <ul style="list-style-type: none"> <li>- Ethernet (wired)</li> </ul>			



To Certificate No.: EN-ST-000261

Date : 04-11-2019

The approved component/system is described as follows:

Type of document	Manufacturer's identification	Date	Number of Pages
Installation Manual: - IRIS-4 160 Series	Quick Installation and Maintenance Guide, PDK-12508, Version 3.0	04.11.2019	16
Technical Documents: - Bill of material	IRIS-4 160, Revision D1	10/2019	9
- Drawing (Assembly PCB)	Assembly Top Layer Assembly Bottom Layer Assembly Drill	12.05.2018	3
- Circuit diagram	IRIS-4 160, Revision D1	10/2019	10
- Drawing (Label)	Light pipe, Rev. 02	08.08.2014	1
- Drawing (Label)	Front Housing, Rev. 03-2	24.09.2019	1
- Drawing (Label)	Rear Housing, Rev. 06-2	09.10.2019	1
- Drawing (Label)	Label-NG-034, Rev. 1.0	15.08.2018	1
- Drawing (Label)	Label-NG-029, Rev. 1.1	12.06.2018	1
- Drawing (Label)	Carton-NG-010, Rev. 1.0	15.08.2018	1



**Enclosure 3**

**Sheet 1**

To Certificate No.: EN-ST-000261

Date : 04-11-2019

Instructions for the application of the approval component/system (see enclosure 1):

No